



# Certificate

## Indoor Air Comfort Gold

noracare® in a system

*Certified Product*

nora systems GmbH

*Applicant*

The product complies with Indoor Air Comfort Gold requirements for product type, version 6.0 (2017). These include both inspections of factory production according to DIN 18200 and VOC testing according to EN 16516 and the ISO 16000 series, each in the latest versions, by an ISO 17025 accredited laboratory, at regular interval.

Indoor Air Comfort Gold certification ensures that low product emission requirements are fulfilled and is a sign of the applicant's focus on quality and contribution to a healthy indoor environment.

Details are defined in Indoor Air Comfort Gold requirements, version 6.0 (2017).

Certificate No.: IACG-31-10-2020

Date: 23 January 2020

Validity of certificate: 10 December 2024, with frequent surveillance and retesting.

Compliance with Indoor Air Comfort Gold means compliance with VOC requirements on low emitting products of:

Belgium regulation, France VOC class A+, Germany (AgBB/ABG), BREEAM international, BREEAM NOR, BREEAM NL, LEED, WELL Building, SKA Rating, French HQE certification, Italian regulation on GPP (Green Public Procurement), BVB (Sweden), Eco Product Norway, DGNB, Nordic Swan, Blue Angel DE-UZ 120, Austrian ecolabel criteria UZ 42, M1, Danish Indoor Climate Label, Singapore Green Label, GreenTag Australia.

Thomas Neuhaus

Head of Certification Body



Product Testing



# Appendix to Certificate

IACG-31-10-2020

nora systems GmbH  
Höhnerweg 2-4  
69469 Weinheim  
Germany

receives the Indoor Air Comfort Gold certificate with validity 10 December 2024 for below product group, including subgroups and individual products listed in the following table:

Product group	Products
noracare® in a system	<p>noracare® uneo noracare® seneo</p> <p>In combination with: nora AC 100, nora L 1000, nora SF 1001, nora PRP 101</p>

The products in this group are based on identical or similar recipe and are produced under equivalent conditions. Grouping of the products and inspection of the production process is part of the Indoor Air Comfort Gold certification. A worst-case product, which is representative for the whole group, is being tested frequently.

The emissions of styrene was below 30 µg/m<sup>3</sup> and the emissions of naphthalene was below 2 µg/m<sup>3</sup>.