



Certificate

Indoor Air Comfort Gold

norament 928 in a system

Certified Product

nora systems GmbH

Applicant

The product complies with Indoor Air Comfort Gold requirements for product type, version 6.0 (2017). These include both inspections of factory production according to DIN 18200 and VOC testing according to EN 16516 and the ISO 16000 series, each in the latest versions, by an ISO 17025 accredited laboratory, at regular interval.

Indoor Air Comfort Gold certification ensures that low product emission requirements are fulfilled and is a sign of the applicant's focus on quality and contribution to a healthy indoor environment.

Details are defined in Indoor Air Comfort Gold requirements, version 6.0 (2017).

Certificate No.: IACG-31-07-2017

Date: 19 February 2018

Validity of certificate: 19 February 2023, with frequent surveillance and retesting.

Compliance with Indoor Air Comfort Gold means compliance with VOC requirements on low emitting products of:

Belgium regulation, France VOC class A+, Germany (AgBB/ABG), BREEAM international, BREEAM NOR, BREEAM NL, LEED outside North America, WELL Building, SKA Rating, Italian regulation on GPP (Green Public Procurement), DGNB, BVB (Sweden), Blue Angel RAL UZ 120, Austrian ecolabel criteria, M1, Singapore Green Label, GreenTag Australia.

Thomas Neuhaus

Head of Certification Body

 eurofins

Product Testing



Appendix to Certificate

IACG-31-07-2017

nora systems GmbH
Höhnerweg 2-4
69469 Weinheim
Germany

receives the Indoor Air Comfort Gold certificate with validity 19 February 2023 for below product group, including subgroups and individual products listed in the following table:

Product group	Products
norament 928 in a system	norament 928 ed, norament 928 grano ed In combination with: nora ED 120, nora L 1000, nora PRP 101

The products in this group are based on identical or similar recipe and are produced under equivalent conditions. Grouping of the products and inspection of the production process is part of the Indoor Air Comfort Gold certification. A worst-case product, which is representative for the whole group, is being tested frequently.

The emissions of styrene was below $30 \mu\text{g}/\text{m}^3$ and the emissions of naphthalin was below $2 \mu\text{g}/\text{m}^3$.